

SSO Notification List												
September 2009												
Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	9/4/2009	2500 W. Franklin St	21223	Rags & Grease	Patapsco	4:13	6:04 PM - 10:17 PM	Sewer Water, Paper & Debris	506	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	62065
2	9/8/2009	1308 Wildwood Pkwy	21229	Rags & Grease	Gwynns Falls	1:15	4:15 PM - 5:30 PM	Sewer Water & Paper Debris	150	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	62163
3	9/8/2009	644 E. Clement St	21230	Roots	Gwynns Falls	1:31	8:22 PM - 9:53 PM	Sewer Water	Evidence of an Overflow	Relieved Choke with Cleaning Machine	Turned over to be CCTV'ed	62171
4	9/9/2009	507 W. Preston St	21201	Rags & Grease	Inner Harbor	1:37	6:28 PM - 8:05 PM	Sewer Water & Paper Debris	485	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	62208
5	9/11/2009	400 E. Eager St	21202	Heavy Rain & Infil/Inflow	Inner Harbor	2:15	4:05 PM - 6:20 PM	Sewer Water & Grease	9,450	Waited for Rain to Subside	No Preventative actions Reported	62292
6	9/11/2009	1700 Falls Road	21201	Heavy Rain & Infil/Inflow	Jones Falls	4:03	5:57 PM - 10:00 PM	Sewer Water, Paper & Debris	6,075	Waited for Rain to Subside	No Preventative actions Reported	09-00749281
7	9/11/2009	406 W. Cold Spring Ln	21212	Debris	Herring Run	2:50	4:10 PM - 7:00 PM	Sewer Water	850	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	100327
8	9/11/2009	4 N. Bethel St	21231	Grease	Inner Harbor	5:42	3:03 PM - 8:45 PM	Sewer Water	5,030	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	62274
9	9/12/2009	2645 Hampden Ave	21211	Roots	Gwynns Falls	6:00	11:49 AM - 5:49 PM	Heavy Gray Water	360	Relieved HC Choke with Cutter Machine	Turned over to be CCTV'ed	100756
10	9/14/2009 to 9/16/2009	1700 Canton Dr	21224	Roots	Patapsco	45:50	1:40:00 PM 9/14/09 - 9/16/09 11:30 AM	Heavy Gray Water	Evidence of an Overflow	Turned over to Construction for Repairs	No Preventative actions Reported	100812
10	9/17/2009	2600 Gwynns Falls Rd	21216	Roots & Grease	Gwynns Falls	17:00	5:00 PM - 10:00 AM	Gray Water & Paper	1,020	Relieved M/L Choke with Pressure Truck	CCTV'ed M/L and put on Grease Control	100888
11	9/23/2009	3337 Winterbourne Rd	21216	Rags & Grease	Gwynns Falls	1:00	11:00 AM - 12:00 PM	Heavy Gray Water	180	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	101119
12	9/24/2009	1612 N. Warwick Ave	21216	Rags	Gwynns Falls	1:00	11:00 AM - 12:00 PM	Heavy Gray Water	60	Relieved HC Choke with Cutter Machine	Turned over to be CCTV'ed	101156
13	9/30/2009	2400 W. Cold Spring Ln	21209	Rags & Grease	Gwynns Falls	1:00	10:00 AM- 11:00 AM	Heavy Gray Water	300	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	101309
								TOTAL	24,466			